



**SECTION A-A**

**NOTES**

1. REFER TO WATER CYCLE MANAGEMENT GUIDELINES AND SOID GUIDELINES FOR DESIGN GUIDANCE.
2. ENGINEERING WORKS TO BE DESIGNED IN ACCORDANCE WITH COUNCIL'S ENGINEERING DESIGN GUIDELINES.
3. SEDIMENTATION BASIN SHALL BE CONSTRUCTED WITH A HARD BASE TO ASSIST WITH MAINTENANCE. THE BASE MUST HAVE A BEARING CAPACITY TO SUPPORT MAINTENANCE MACHINERY WHEN ACCESS IS REQUIRED INTO THE BASIN.
4. REFER TO COUNCIL'S LANDSCAPE DESIGN GUIDELINES FOR TOPSOIL, MULCH AND PLANTING SPECIFICATIONS.
5. AQUATIC VEGETATION IS REQUIRED IN THE MACROPHYTE ZONE TO MINIMISE ALGAL BLOOMS AND EUTROPHICATION.
6. CONCRETE RAMP AND PAD TO BE 32MPA WITH SL82 REINFORCING STEEL AND AND 150mm MIN THICKNESS. SUB-BASE TO BE FOR COMPACTED 95% AND 100mm MIN THICKNESS.
7. MAINTENANCE ACCESS TRACK TO BE 2% STABILISED GRAVEL 3m WIDE AND 150mm MIN THICKNESS.
8. FOOTWAY ACCESS TO OUTLET STRUCTURE TO BE NO FINES CONCRETE, 1m WIDE AND 125mm MIN THICKNESS.
9. CONCRETE BYPASS WEIR AND INLET TO BE 25MPA WITH SL82 REINFORCING STEEL AND 150mm MIN THICKNESS.
10. ROCK FOR BY-PASS WEIR AND INLET STONE PITCHING TO BE 250-300mm HARD DURABLE ROCK IN ACCORDANCE WITH ENGINEERING GUIDELINES.

07	6 AUG 16	REVISE NOTES	WORK TO FIGURED DIMENSIONS - DO NOT SCALE - THIS DRAWING IS SUBJECT TO COPYRIGHT AND IS THE PROPERTY OF LAKE MACQUARIE CITY COUNCIL. PERSONS MUST NOT RELY ON THESE STANDARD DRAWINGS AS THE EQUIVALENT OF, OR A SUBSTITUTE FOR, PROJECT-SPECIFIC DESIGN & ASSESSMENT BY A QUALIFIED PROFESSIONAL.		126-138 MAIN ROAD SPEERS POINT PHONE (02)4921 0333 WWW.LAKEMAC.COM.AU	SHEET: 1 OF 1 DRAWING No: EGS4-413 VERSION: 07
06	17 JUNE 15	REVISE NOTES				
05	11 DEC 13	REVISE NOTES				
04	18 OCT 12	REVISE NOTES				
VERSION	DATE	COMMENTS				